



**Mrs. Evi Smets**  
**Arte nv**  
**Industriezone "De Waerde"**  
**Senator A. Jeurissenlaan 1210**  
**B-3520 Zonhoven**

**Your message - reference**

-

**our reference**

PW/2112

**Gent**

2016-12-23

Certification report 16/2112

---

## 1. Description of the wall covering:

<b>Product family</b>	Type 07: Decorative wall covering consisting of: Non-woven backing made of cellulose fibres and binder Glue made of polyvinylacetate Layer of natural fibres Printing layer
<b>Total mass</b>	208 g/m <sup>2</sup> - 700 g/m <sup>2</sup>

## 2. Test results:

Classification according to EN13501-1:2007+A1 (2009)

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**

**GENT •** Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)

**VAT •** BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

**addressee**

Arte nv

**our reference**

PW/2112

**Gent**

2016-12-23

**page**

2

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

**B - s1, d0**

Glued (starch glue applied at the rate of 200 g/m<sup>2</sup>) on a fibre-cement substrate with a fire performance of class A2-s1, d0 (EN 13238) excluding paper faced gypsum plasterboard / without air gap

**Related commercial names to this product group**

Bark Cloth  
Boracay  
Carabao  
Coriolis  
Heliodor  
Ligna  
Oculaire  
Revera  
Xanadu  
Wild

**The obtained classification is based on the next test reports**

CSTB: RA13-0368  
CSTB: RA14-0038

**Validity of the certificate**

17/02/2019

Petra Wittevrongel

Product Certifier

